

SERIES NG 500 **DRAINAGE AND SERVICE DUCTS**

Contents

Clause	Title	Page
NG 501	(02/20) Pipes for Drainage and Service Ducts	2
NG 502	(02/20) Excavation for Pipes and Chambers	3
NG 503	(02/20) Bedding, Laying and Surrounding of Pipes	3
NG 504	(02/20) Jointing of Pipes	4
NG 505	(02/20) Backfilling of Trenches	4
NG 507	(02/20) Chambers	4
NG 508	(02/20) Gullies and Pipe Junctions	5
NG 509	(02/20) Testing and Cleaning	6
NG 510	(02/20) Surface Water Channels and Drainage Channel Blocks	6
NG 511	(02/20) Land Drains	6
NG 512	(02/20) Backfilling to Pipe Bays and Verges on Bridges	7
NG 513	(02/20) Permeable Backing to Earth Retaining Structures	7
NG 514	(02/20) Fin Drains	7
NG 515	(02/20) Narrow Filter Drains	9
NG 516	(02/20) Combined Drainage and Kerb Systems	9
NG 517	(02/20) Linear Drainage Channel Systems	10
NG 518	(02/20) Thermoplastics Structured Wall Pipes and Fittings	10
NG 521	(02/20) Low Pressure High Volume Jetting of Drainage Systems	12
NG 523	(02/20) Grassed Surface Water Channels	13F
NG 524	(02/20) Combined Surface Water Channel and Pipe (Concrete)	13F
NG 525	(02/20) Reservoir Pavements	13F
NG	(02/20) Sample Contract Specific Appendices	A1

DRAINAGE AND SERVICE DUCTS

NG 501 (02/20) Pipes for Drainage and Service Ducts

1 (02/20) Pipes can be made of materials that deflect relatively little under load before cracking (rigid pipes) or of materials that will tolerate large deflections under load before inward buckling occurs (flexible pipes). Flexible joints enable either type of pipe to take up differential settlement within the ground.

2 (02/20) The specification includes a wide range of pipe materials. The Contractor should normally be offered in contract specific Appendix 5/1 the full selection of alternative pipe and bedding combinations determined in accordance with CD 533 (DMRB 4.2.5) as detailed in the HCD for pipes up to 900 mm internal diameter. The required pipe stiffness and impact resistance for plastics pipes should be specified in contract specific Appendix 5/1. The requirements for thermoplastics pipes and fittings will normally be as in Clause 518 with raw material and quality control requirements as in NG 518. Piped culverts up to 900 mm internal diameter should be specified in Series 500. Drains, box culverts, piped culverts (and other drains) of clear span or internal diameter exceeding 900 mm are subject to Overseeing Organisation's technical approval and should comply with Series 2500. A box culvert should not be specified where either a (concrete) box culvert or a (corrugated steel) piped culvert would be technically acceptable. Most of the pipes included in the specification will normally be satisfactory from the hydraulic flow capacity factor. However some products, especially corrugated pipes, can vary from the norm (eg clay/concrete) and between manufacturers. The effect of a rougher pipe should be considered on the system as a whole and not just on the length in question. A pipe which is not acceptable on a straight exchange basis may be acceptable if diameters on adjacent lengths are adjusted. Contract specific Appendix 5/1 should provide the basis on which the Contractor is to submit his proposals for pipe types and makes.

3 (02/20) Any tendency to attack by acidic ground water or sulfates present in the backfill or the ground should be taken into account when the use of concrete, steel or iron pipes is being considered for inclusion in the schedule of acceptable alternatives in contract specific Appendix 5/1. The advice described in Clause NG 1704 should be considered regarding the risk of thaumasite sulfate attack on concrete used in drainage. When acid soils (pH less than 6.5) are encountered, expert advice should be sought. There is some evidence that pipes made of sulfate-resisting cement will tolerate a pH as low as 6.0. The limiting value may be reduced to pH 5.5 when a bitumen coating is applied to the pipe. Sulfate attack on concrete is dealt with in Building Research Establishment Special Digest 1. More detailed information may be obtained from the manufacturers. Protection to the lower third of the inside of corrugated steel piped culverts by means of an asphalt or in situ concrete coating will be required where stones and rocks are likely to be carried by the flow. Iron pipes are treated with a bitumen coating and have high durability in most soils, but when acid conditions are known to be present the additional protection of a polyethylene sleeve is desirable. Clay, GRP and PVC-U pipes are resistant to a wide range of groundwater chemicals.

4 (02/20) For corrugated steel pipes of lock seam fabrication with a diameter not exceeding 900 mm, the specification of metal thickness should be given in contract specific Appendix 5/1. The tables issued by manufacturers recommend thicknesses corresponding to the diameter and depth of fill above the pipe.

5 (02/20) Pipes of more than one type within any individual drain or service duct between consecutive chambers will be exceptional. Whatever the circumstance giving rise to the proposal, consideration should be given to whether the joint between the two pipes will provide an appropriately watertight joint and a smooth inner transition for rodding purposes.

6 (02/20) Plastics pipes may deteriorate after a long period in sunlight. Where pipes have been manufactured and stored before being delivered to the site, it may be necessary for the Contractor to cover them until they are installed.

7 (02/20) Any individual cable duct under a road may have to accept a power or a communication cable although these are normally placed in separate ducts. Certain pipe materials have been excluded from the specification for use as ducts because cables cannot be readily drawn through them. Clauses NG 518, NG 1421 and NG 1530 give further information on the use of ducts for electrical work. Ducts should be scheduled in a similar way to pipes in contract specific Appendix 5/2. Any special requirements of Statutory Undertakers etc. should be stated clearly.

8 (02/20) Trenchless and minimum dig installation is the means of installing, replacing and renovating pipes, ducts and small tunnels with minimal or no excavation from the surface. MCHW 5, Series 8000 covers the requirements for trenchless and minimum dig installation of highway drainage, service ducts, sleeves and culverts up to and including 900 mm nominal internal diameter or width. The information required from the designer/compiler that will detail the performance required from the trenchless installation should be given in NG Sample Appendix 80/1 (MCHW 5.8.3).

NG 502 (02/20) Excavation for Pipes and Chambers

1 (02/20) In the preparation of contract specific Appendix 6/3, it may be considered appropriate to permit battering of slopes where this would not affect adversely the permanent works or the basis of structural design of the pipe/trench.

2 (02/20) In the event of excavation to a greater depth than necessary the Contractor is obliged to reinstate. The use of ST1 concrete to remedy excess excavation should be restricted to areas where compaction is impracticable. Where the floor of the trench passes through a localised area of disturbed and uncompacted soil or softened clay further excavation and replacement with appropriate material may be required to allow pipe laying to proceed.

3 (02/20) Where pipes are to be installed beneath heavily trafficked existing roads, etc, where it is undesirable that the existing ground surface should be disturbed, consideration should always be given to the possibility of inserting the pipe by suitable thrustboring or jacking processes.

NG 503 (02/20) Bedding, Laying and Surrounding of Pipes

1 (02/20) Pipe bedding material should be readily obtainable since a wide range of gradings and sizes complying with BS EN 13242 are permitted. Pipe bedding material needs to flow readily and compact uniformly, thus a low coefficient of uniformity is necessary. In order to make savings in coarser granular materials a sand bed may be adopted. Surround to pipes should be in bedding material or acceptable material (Class 8) as appropriate to the alternatives shown in the HCD. Coarse granular material may consist of natural aggregate, recycled coarse aggregate, recycled concrete aggregate, artificial or blended combinations of these aggregates, which satisfy the requirements of the specification.

2 (02/20) The limiting values in sub-Clauses 503.4 and 503.5 have been chosen to ensure that problems do not occur due to oxidation of reduced sulfur compounds such as pyrite. Further guidance is given in sub-Clause NG 601.8 and Clause NG 644.

3 (02/20) A distinction is to be made between the requirements of bedding, haunching and surrounding and those of backfilling. The former comprise all operations of trench fill up to a level 300 mm above the top of the barrel of the pipe. Backfilling constitutes the remaining operations up to ground level in verges and open ground and up to formation or sub-formation level under carriageways. Work above formation level constitutes construction or reinstatement of the pavement (see NG 706).

4 (02/20) Concrete surround should be used exceptionally, eg for protection of pipes against mechanical damage from subsequent operations after construction of the pipeline and where remedial measures due to over excavation are required. Protection of existing pipes where necessary may take the form of a concrete arch or slab above the pipe.

NG 504 (02/20) Jointing of Pipes

1 (02/20) Pipe joints for surface water drains, unlike foul drains, do not always have to be completely watertight. Small amounts of seepage as allowed in sub-Clause 509.7 can be tolerated particularly where pipes are laid in cuttings or below the water table. However, joints in pipes in soils that are predominantly fine sands or coarse silts should have watertight joints to prevent soil particles passing through the joint into the pipe leaving voids on the outside of the pipe. Where fine sands or coarse silts might be a problem but the more expensive rubber ring flexible joint is unwarranted, consideration can be given to certain proprietary wrap type joints that are available. These may also be specified where root penetration needs to be prevented. Requirements should be given in contract specific Appendix 5/1.

2 (02/20) Most watertight joints will be flexible joints although rigid joints are occasionally used on clay pipes. In and under embankments, or if differential settlement is expected in compressible soils subject to non-uniform loading, then flexible joints and (except for pipes below the water table laid in non-erodible soils) watertight joints should be specified. The maximum length of pipe between flexible joints may have to be limited where considerable movement is expected. The limits of the exclusions should be shown in contract specific Appendix 5/1.

3 (02/20) Culverts are generally considered to be drains but they do not necessarily require watertight joints. Where watertight joints are required for culverts this should be stated in contract specific Appendix 5/1.

NG 505 (02/20) Backfilling of Trenches

1 (02/20) Type A material is intended for sub-soil drainage. The specification permits a wide grading envelope from BS EN 13285 so that local sources may be used as far as possible. When soils to be drained require a particular grading of filter aggregate it can be specified under the heading Type C in Table 5/5. The design should be based on knowledge of local sources of supply, BS EN 13285 and Transport and Road Research Laboratory Report LR 346 which gives guidance on the design of filter materials. Type B material is a coarse aggregate complying with BS EN 13242, intended for use where the drain is designed to intercept surface water flowing to the pipe. Grit from the carriageway may slowly block this type of filter and it may require cleaning or replacement periodically. Where filter drains are located close to carriageways and are likely to be overrun by traffic, methods of preventing the problem of 'stone scatter' should be considered. Some possible solutions are shown on HCD Drawing Number B15.

2 (02/20) The limiting values in sub-Clauses 505.9 and 505.10 have been chosen to ensure that problems do not occur due to oxidation of reduced sulfur compounds such as pyrite. Further guidance is given in sub-Clause NG 601.8 and Clause NG 644.

3 (02/20) Filter drains can be constructed by machines that excavate the trench, support the sides, lay the pipe and backfill with filter material in one operation. The trench is normally constructed with a semi-circular floor providing a most effective support to the pipe without further bedding. As contamination of the filter material is minimized by the supporting shutter attached to the machine a much narrower trench than that achieved by conventional excavation is possible.

4 (02/20) Where geotextile membranes are specified to be in accordance with Clause 609 the compiler should use contract specific Appendix 6/5 to detail the performance requirements for the geotextile.

NG 507 (02/20) Chambers

1 (02/20) Concrete chambers, precast or cast in situ against forms, do not require strengthening with additional concrete surround. Access shafts in precast concrete should be strengthened, however, as a protection against loads from backfilling operations. Brick chambers, including shafts do not need a concrete surround for strengthening. It may however be necessary to backfill with concrete where space is insufficient to permit compaction of one of the earthwork's acceptable materials. Inspection chambers are those that can be maintained from the surface and do not need to be entered. The types of brick to be used for brick chambers, and beneath chamber frames, in normal circumstances are specified in Clause 2406. Where a different type of brick is required this should be described in contract specific Appendix 24/1. Any brickwork upon which chamber frames are seated should be properly constructed.

2 (02/20) Safety precautions require that chamber covers have a minimum opening as shown on the HCD Drawings where personnel may be required to enter completely. In carriageways, hard shoulders and verges, chamber covers, frames and gratings should be at least Class D400. Where, exceptionally, covers have to be located in areas subjected to large numbers of high speed heavy goods vehicles, Class E600 chamber covers, frames and gratings should be considered. Advice may be sought from the Overseeing Organisation. It will normally be expected that the minimum frame depth is 150 mm. When specifying cover types, Compilers should have regard to the weight of each element of the cover so that it could be lifted safely and should review the measures available to prevent covers falling into the chamber when being removed. Reference should be made to the HSE Manual Handling Operations Regulations and guidance, where appropriate.

Seating of covers within frames is not required unless specified in contract specific Appendix 5/1.

3 (02/20) It may be necessary, due to constraints in pipe lengths to vary the lengths of the articulated section described in sub-Clause 507.17. However, the principle of having the joint nearest the chamber as close as possible to the chamber and the next joint positioned so as to give an effective length of intervening articulated pipe, free from constraint by the trench bottom, should be maintained.

4 (02/20) BS EN 124 makes no reference to coatings. Many manufacturers apply a coating in order to prevent discolouration of the castings while in stock or in transit. However, BS 7903 : 1997 states that short term coatings offer no lasting product enhancement and any surface oxidation of the cast iron has no detrimental effect upon its use.

5 (02/20) It is essential that the in-service skid resistance of a cover is suitable for the conditions of use. The site categories given in CS228 (DMRB 7.3.1) should be used as guidance. To convert the SCRIM Coefficient (SC) figures given in HD 28 to the Polished Skid Resistance Value (PSRV) given in BS 9124 the following formula can be used.

$$\text{PSRV} = (\text{SC} + 0.05) \times 100$$

It is important to note that the skid resistance of the cover in use will depend upon a number of factors. These factors might include the material from which the cover is made, the type of pattern on the surface of the cover in use, the type of trafficking that the cover is subjected to, environmental conditions etc.

The actual skid resistance of the cover in use at any point in time is likely to be different from that obtained on the cover at the point of manufacture or installation.

Where a specified level of skid resistance in use is required then it is important that a cover is selected that can withstand the trafficking expected at a particular site so that the level of polishing does not reduce the frictional properties of the cover to a level below that required.

The Unpolished Skid Resistance Value (USRV) and/or the use of a pattern on the surface of the cover does not in itself ensure satisfactory levels of skid resistance for all situations of use.

6 (02/20) The use of proprietary bedding components of different specifications may be permitted subject to them being demonstrated as equivalent and meeting the requirements stated in Clause 104.

Reinstatement of Surrounding Flexible Carriageway

7 (02/20) Where the space between the frame and the sides of the excavation at all levels is inadequate for mechanical compaction equipment, a proprietary self-setting fill material compatible with the bedding material may be used when installed to the manufacturer's instructions.

NG 508 (02/20) Gullies and Pipe Junctions

1 (02/20) Trapped gullies are essential only on connections to combined or foul drains in urban areas or on roads where traps are regularly and frequently emptied. In terms of pollution there is little difference in water quality between the flow through trapped or untrapped gullies although a trapped gully would normally retain the contents of a vehicle's sump in the event of an accident. Further advice on sumpless gullies can be found in CD 527 (DMRB 4.2.3).

- 2 (02/20) Where concrete trapped gullies are cast in situ using a permanent plastic mould, the part forming the trap should be equal in all respects to that of precast concrete or clay gullies.
- 3 (02/20) Any brickwork upon which gully frames are seated should be properly constructed.

NG 509 (02/20) Testing and Cleaning

- 1 (02/20) Requirements for drain testing should be specified in contract specific Appendix 1/5. The air test does not indicate the location of any large leaks that may be present. A water test may follow the failure of an air test.
- 2 (02/20) Fall of the test water level may be due to one or more of the following causes:
 - (i) Absorption by pipes or joints.
 - (ii) Excessive sweating of pipes or joints.
 - (iii) Leakage from defective pipes or joints or plugs.
 - (iv) Trapped air.

Some pipes absorb more water or trap more air at the joints than others. Allowance should be made for this by adding water to maintain the test head for appropriate periods. While the aim should be to commence the test period proper 2 hours after filling, the appropriate period may best be determined by conferring with the pipe manufacturers.

- 3 (02/20) When checking pipelines, Closed Circuit Television (CCTV) inspection is a suitable alternative to the mandrel test. However, CCTV inspection should always be used on foul sewers and connections to sewers. To avoid subsequent disputes it is essential to liaise with the drainage authority when checking connections to existing sewers to ensure acceptability of the work and to determine the extent of the survey required on existing sewers.
- 4 (02/20) The test for partly watertight joints must be carried out before the pipe is laid because the water escaping from the joint has to be measured. The purpose of the test is to prove that the joint does not leak so excessively as to cause piping in any granular surround.
- 5 (02/20) Series 9000 (MCHW 5.9, Parts 1 to 5) contains the documentation for the specialist activity of the CCTV survey of highway drainage systems. The specification covers all types of pipes with diameters up to and including 900 mm including sub-surface drainage and other non-piped systems that are being introduced. Pipes and conduits in excess of 900 mm are classified as structures that require technical approval; however, this technique is equally applicable to the remote inspection of these structures up to 1800 mm diameter.
- 6 (02/20) When checking foul drains and their connections to existing sewers, it is essential to liaise with the drainage authority to ensure acceptability of the work and to determine the extent of the survey, including CCTV survey, required.

NG 510 (02/20) Surface Water Channels and Drainage Channel Blocks

- 1 (02/20) Requirements for these should be included in contract specific Appendix 5/3 and be compatible with the relevant HCD Series B and Series F drawings.

NG 511 (02/20) Land Drains

- 1 (02/20) New highway construction works are likely to disturb and render ineffective existing drainage systems in adjoining land; it will therefore be necessary for the Contractor to carry out without delay any such temporary or permanent remedial works as may be described in Appendix 5/1. The ideal arrangement for land drainage remedial works is that the system of drainage of land adjoining the road should be separate from the road drainage so that the reinstatement of the system is on the owner's land and the matter falls to be dealt with by the District Valuer as a matter of accommodation works. When such arrangements are not practicable or the cost is excessive, the existing land drainage system should be linked with the drainage system of the road.

NG 512 (02/20) Backfilling to Pipe Bays and Verges on Bridges

1 (02/20) Any special filling material, e.g. lightweight material, should be described by providing additional information on the drawings, cross-referenced in contract specific Appendix 5/1.

NG 513 (02/20) Permeable Backing to Earth Retaining Structures

1 (02/20) For granular backing, Type C has been added to allow for the design of a filter compatible with the particular type of filling to be employed adjacent to the structure. It is recognised that the use of Type A will not always meet the piping and permeability ratio criteria.

2 (02/20) Fin drains are not allowed as permeable backing to structures because it is not yet possible to demonstrate that any of them will have the required design life of 120 years.

NG 514 (02/20) Fin Drains

1 (02/20) These consist of a core which will allow the free drainage of water entering through geotextile filters on the outside of the core. The core may consist of nets, webs, grids or preformed plastic sheets or strips. Some restrict entry through one side or confine water entering to part of the cross-sectional area of the core. Any such restrictions should be taken into account in assessing the flow characteristics of the drain. Fin drains are intended to be used for subsurface drainage, as shown in the HCD, to remove and keep out water from the road structure. They are provided to remove surface infiltration from the pavement layers, to prevent infiltration from shoulders, medians and verges into the pavement, and sometimes to cut off shallow groundwater seepage. They thus act as low-capacity filter drains. In normal circumstances, the Contractor should be permitted the choice of any of the types shown in the HCD. If however, for engineering reasons, exclusion of a particular type is required, this should be stated in contract specific Appendix 5/4. The minimum values for mechanical and hydraulic properties given in Clause 514 are intended for this particular usage and may not be relevant to fin drains used elsewhere. Additionally, the Clause requires specification of the pore size distribution of the geotextile and the inflow and discharge capacity of the fin drain determined for the site conditions.

2 (02/20) The pore size for the geotextile should be selected using filtration criteria to be compatible with the adjacent soil or construction layer in order to prevent the occurrence of piping. The following soil retention criteria may be used in determining O_{90} . Other criteria are available.

(02/20) **TABLE NG 5/1 Uniformity Coefficient of d_{60}/d_{10} Soil Woven and Meltbonded Geotextiles Needle-punched Geotextiles**

Uniformity Coefficient of d_{60}/d_{10} Soil	Woven and Meltbonded Geotextiles	Needle-punched Geotextiles
1 to 5	$O_{90}/d_{50} = 1$ to $O_{90}/d_{50} = 3$	$O_{90}/d_{50} = 4$ to $O_{90}/d_{50} = 6$
> 5	$O_{90}/d_{90} < 1$ or $O_{90}/d_{50} < 3$	$O_{90}/d_{90} < 1.8$ or $O_{90}/d_{50} < 6$

d_n = n% size in base soil (n% is finer)

O_{90} = 90% opening (pore) size of geotextile
(90% of openings are smaller)

In general, it will be sufficient to specify only the maximum value of O_{90} that will satisfactorily retain the adjacent soil particles as the minimum O_{90} size will be governed by the permeability requirements in sub-Clause 514.4. Geotextiles will usually be in contact with variable surface soil deposits, as well as the more uniform materials composing the pavement, and great accuracy in specification may not therefore be feasible. The finest O_{90} relevant to the various soil deposits likely to be encountered may be specified. An O_{90} value of 1 mm should be considered as the upper limit even with large grained soils. With cohesive fine grained soils such as clays the use of the above

criteria will result in such small pore sizes that sufficient water flow cannot be obtained. In such cases the cohesion of the soil particles themselves is relied upon to prevent piping and a maximum O_{90} value of 250 microns may be chosen. Dispersive silts can present particular problems and in these cases the O_{90} value may be less than 250 microns: however, the value to be specified should be carefully considered in order both to avoid piping and to ensure sufficient long-term flow.

3 (02/20) Sub-Clause 4 of Clause 514 requires the designer to specify the flow rate normal to the geotextile wrapping to the filter drain. The specified flow rate should incorporate a margin of safety to allow for the impeded flow due to the adjacent core of the fin drain (or the filter material in a narrow filter drain) as described in sub-Clause 14 of Clause 514. It should also incorporate a substantial margin to allow for the reduction of flow with time due to clogging. The long-term flow through a geotextile in contact with the coarse gravel may not differ significantly from the short-term flow measured in the standard test. In contrast, the long term flow through a geotextile in contact with a dispersive silt may be one thousand times smaller than the short-term flow. There is some evidence that chemical or biological leachates may also cause severe clogging.

Different rates of flow into the two sides of the fin drain may be specified, for example, if the water flows from the verges are expected to be very different to those from the pavement structure. A value of 10 litres/m²/sec is suggested for use against the unbound mixture for subbase and capping specified in Series 600 and 800. Very much smaller values are adequate for soils and backfills other than coarse gravels, and possibly dispersive silts or contaminated sites. It should be appreciated that, because of such long-term effects, these flow rates should not be used to determine the in-plane design requirements of the fin drain.

4 (02/20) Clause 514 requires specification of the in-plane flow capacity of the fin drain. This design capacity should allow for infiltration through the pavement and verges and any other source of ground water ingress. Until more accurate means of establishing infiltration rates through the pavement are available a value not less than the mean intensity of a one year 2 hour rainfall should be assumed. The fin drain Type 5 of Drawing F18 in the HCD acts both as a filter drain and a carrier pipe. Thus in-plane flow must be specified for flow both along the drain parallel to the road edge and near-vertically down the drain. For all other drain types, only near-vertical downward flow need be specified. Fin drain Type 10 in Drawing F21 should either have an impermeable side or be covered by an impermeable membrane unless no significant blocking of the core will occur during the slip-forming of the channel.

Fin drains are normally laid at constant depth below the carriageway and their gradient will therefore follow that of the road. Drainage capacities should be designed for these gradients and outfall lengths determined accordingly. For drain Type 5 the flow rates that are stated in contract specific Appendix 5/4 should be the capacity required linearly extrapolated to the standard gradients in Table 5/8. Where fin drains utilise a pipe, capacities may be obtained from hydraulic tables and the required diameter specified.

5 (02/20) Sub-Clause 10 of Clause 514 specifies the use of as-dug material for trench backfill. If this material when compacted is sufficiently less permeable to affect the efficiency of the drain, or contains stones larger than about 100 mm which could damage the drain, an alternative material compatible with the geotextile should be used.

6 (02/20) Proper functioning of the fin drain and its ancillary components depends critically on adequate installation and joining procedures.

Fin drains can be problematical during construction phase for the following reasons.

- (i) They do not provide immediate drainage for the unpaved subbase.
- (ii) They are not designed for surface water flows.
- (iii) Fine particles transported by surface water or vehicles may clog the filter or silt the drain.
- (iv) They may be damaged by the passage of construction traffic.

Appropriate protection measures must be taken, eg polythene sheeting, temporary drainage channels, or warning fence. Alternatively, the drains may be installed towards the end of the construction phase.

7 Fin drain components that fall under the scope of the Construction Products Regulation are required to have a declaration of performance in accordance with the relevant harmonised standard. All fin drains must be the subject of product acceptance scheme certification which certifies the values achieved for the specified properties when tested in accordance with Clause 514. Fin drains are available in a variety of configurations with different types of core structure. It is intended that whenever the Contractor proposes the use of any fin drain he must supply copies of the appropriate product acceptance scheme certificate(s) to confirm that the product complies with the contract requirements. (Further guidance may be sought from the Overseeing Organisation.)

8 (02/20) The Contractor should be offered a selection of fin drain types from a list of acceptable alternatives (see HCD Drawing F18) listed in contract specific Appendix 5/4.

NG 515 (02/20) Narrow Filter Drains

1 (02/20) Narrow filter drains are intended for use as edge of pavement sub-surface drains and are suitable alternatives to fin drains for this purpose. Both types have the same requirements of performance and the guidance given in NG 514 is equally applicable to determining the soil retention and permeability criteria of the geotextile used in narrow filter drains and to the discharge capacity of the drain. In normal circumstances, the Contractor should be permitted the choice of any of the types shown in the HCD. If however, for engineering reasons, exclusion of a particular type is required, this should be stated in contract specific Appendix 5/4.

2 (02/20) In drain Type 8 the filtration function is achieved by a granular filter material and geotextile sock and in Type 9 by means of a geotextile wrapping to the drain. Both filters should be designed to be compatible with the adjacent soil or construction layer. For the Type 8 drain granular material the category for tolerances at mid-size sieves should be specified in contract specific Appendix 5/4. The geotextile sock round the pipe is a second stage filter where it is required to retain the particles of the first stage granular material. However, the pipe when laid in the narrow trench may have insufficient granular surround for fully effective first stage filtration to be achieved. Pore sizes for the sock material should therefore be designed to also retain the finer soil particles outside the trench.

3 (02/20) The specification for granular material in Table 5/8 is intended to permit the widest range of available material to be used. These limits have been set to reduce the risk of damage to the geotextile, to avoid gap grading of the filter material and to ensure an adequate degree of permeability. For the material as specified a minimum value of permeability of about 1×10^{-4} m/second which is similar to that obtained by a clean coarse sand may be assumed. A higher permeability will rarely be necessary but if required it may be specified in contract specific Appendix 5/4.

4 (02/20) Narrow filter drains require protection during the construction phase similar to that provided for fin drains (see NG 514.6).

5 (02/20) The geotextiles used in narrow filter drains are required to have a declaration of performance in accordance with the Construction Products Regulation and harmonised standard BS EN 13252.

NG 516 (02/20) Combined Drainage and Kerb Systems

1 (02/20) The drawings should show the location and gradient(s) of the combined drainage and kerb system, the position of access, silt trap, outfall and end units together with the position and invert level of the surface water outfall connection. The position of any movement joints required in the system, e.g. at joints in bridge decks or concrete carriageways, should be shown. Details of any ducts, cabling, etc, required to pass under the kerb should be shown. The extent of the work to be designed by the Contractor should be clearly defined.

2 (02/20) Combined drainage and kerb systems should be scheduled in contract specific Appendix 1/10 and cross-reference made to the design requirements given in contract specific Appendix 5/5.

3 (02/20) Advice on the location of Class C and Class D systems is given in sub-Clause NG 517.1.

NG 517 (02/20) Linear Drainage Channel Systems

- 1 (02/20) The linear drainage channels specified in Clause 517 may be used in trunk roads including motorways. Class D channels are designed to withstand loadings of all types of road vehicle that are permitted on trunk roads including motorways. Class C channels should only be installed in locations which are protected from direct traffic loading, e.g. in areas behind safety barriers. The range of slot dimensions permissible within Clause 517 is not compatible with safe usage by cyclists and pedestrians, and units with slot dimensions described in Clause 517 should not be used in areas subject to such traffic.
- 2 (02/20) The drawings should show the location of the linear drainage systems and the positions of the surface water outfall chambers into which the systems are to outfall. The position of any movement joints required in the system, e.g. at joints in bridge decks or concrete carriageways, should be shown. Details of any ducts, cabling, etc., required to pass under the systems should be shown. The extent of the work to be designed by the Contractor should be clearly defined.
- 3 (02/20) Linear drainage channel systems should be scheduled in contract specific Appendix 1/10 and cross reference made to the design requirements given in contract specific Appendix 5/6.
- 4 (02/20) Variations to stated dimensions may be considered providing that the product will meet the requirements of this specification.
- 5 (02/20) A system comprising units which may be otherwise too small to accommodate design flows without surcharge may be acceptable in conjunction with the provision of additional intermediate or upstream chambers subject to the following requirements:
- (i) Intermediate chambers should be compatible with the standards of the chambers shown on the drawings and any longitudinal drains connecting such chambers should also be connected into the intermediate chambers.
 - (ii) Not more than one intermediate chamber should be permitted between the upstream and downstream chambers of any drain shown on the drawings.
 - (iii) Not more than one additional chamber should be permitted upstream of each upstream chamber shown on the drawings.

NG 518 (02/20) Thermoplastics Structured Wall Pipes and Fittings

(02/20) General

1 (02/20) Where thermoplastics structured wall pipes and fittings are included in the schedules of permitted alternatives in contract specific Appendix 5/1, the material properties required of the different pipe materials should be specified by the manufacturer in the format given in contract specific Appendix 5/7. The third party certification body verifies these properties against the declared specification. Fulfilment of the performance requirements in conjunction with maintaining the material specification should provide the required durability for the product (ie a minimum life of 45 years).

(02/20) Materials

2 (02/20) Most thermoplastics are stable against common chemicals found in ground water and in surface water runoff. The pipes and fittings should be protected against prolonged exposure to sunlight and it may be necessary for the Contractor to cover the pipes prior to installation.

(02/20) Dimensions

3 (02/20) Dimensions should be measured in accordance with BS EN 476 and should fulfil the requirements of sub-Clause 518.3 and the declared specification (see contract specific Appendix 5/7).

(02/20) Appearance

4 (02/20) The bore of the pipe fittings should be smooth to allow the correct choice of Manning's coefficient for hydraulic design of the system.

(02/20) **Structured Wall Pipe**

5 (02/20) Table 5/9 gives the requirements for structured wall pipes. Where reference is made to British, European or International Standards, these standards should be consulted to discern the relevant test conditions for the product. Where no standard test method is available, the test method is described in sub-Clauses 518.11 to 518.13. Additional information, is given in Table NG 5/2.

TABLE NG 5/2 (02/20) Additional Information for Structured Wall Pipe

Property	Additional Information
General	Quality control and identification
Ring stiffness	6 kN/m ² minimum. Lower stiffness values are permitted if design calculations to BS EN 1295-1 (UK National Annex), based on site specific installation conditions, indicate satisfactory performance. Manufacturer's minimum specification is required for calculation to BS EN 1295.
Creep Ratio	Manufacturer's maximum specification is required for calculation to BS EN 1295. Note: the long term ring stiffness used for design purposes is the two year stiffness and is calculated ¹ by dividing the ring stiffness by the creep ratio.
High volume low pressure jetting	A pass is deemed to also establish satisfactory performance at high volume and low pressure
Longitudinal bending	To reduce the possibility of problems caused by handling on site.
Impact resistance at 0°C	The d50 striker is non-standard
Impact resistance at 23°C	For quality control only
Rodding resistance	To simulate effects of drain rodding
Creep at elevated temperature (ducts)	To simulate the effect of exposure to high temperatures that may occur in power cable ducts
Resistance to point loads (ducts)	Simulate sharp aggregate penetration

Note 1: When carrying out calculations to BS EN 1295 the minimum value for stiffness and the maximum value of creep ratio should be used in order to establish the long term stiffness. For example, a pipe might have a declared minimum stiffness of 4.5 and a maximum declared creep ratio of 3.8. The long term stiffness would be $4.5/3.8 = 1.18$ kN/m². Site-specific calculations, in accordance with BS EN 1295, can be used to establish that the long term deformation will be less than 5% and the safety factor against buckling greater than two.

(02/20) **Fittings**

6 (02/20) As stated in sub-Clause 5 of this Clause the standards should be consulted to discern the relevant test conditions for the product against the requirements given in Table 5/10.

(02/20) **Installation and Handling**

7 (02/20) Care should be taken to prevent changes in line or level when placing the surround material over the pipe crown, as there is the possibility of flotation (see also sub-Clause 503.6). Compaction levels of all sidefill and backfill material must be closely monitored as these have a direct impact on the ground settlement and pipe deflection characteristics. Special precautions may be necessary where the system is subject to high construction loading such as spreader plates.

8 (02/20) Installation and compaction of the pipe and surround are key to the performance and durability of the system. The pipe must be installed to line and level and any pipe that is out of shape should not be installed. The change in shape could be caused by, longitudinal bending, mechanical damage or deformation under lifting and installation. Larger diameter pipes and fittings must be handled with care as they are more likely to suffer impact damage especially at lower temperatures. Reference should be made to the HSE Manual Handling Operations

Regulations and guidance, where appropriate, and care taken whilst using mechanical plant especially near to trench walls. The manufacturer must supply the weight per metre of the pipe and from this information the Contractor is able to assess the lifting needs for installation of the pipe.

(02/20) Test Method for Longitudinal Bending

9 (02/20) The test is intended to eliminate very flexible pipe (eg coilable pipe) and pipe which is so weak that it might deform whilst being handled on site.

10 (02/20) The two level support blocks at least 250 mm wide and of sufficient height to allow the pipe to sag over its length without touching the ground could consist of standard building blocks stood on their ends.

(02/20) Test Method for Rodding Resistance (Internal Puncture)

11 (02/20) The test is intended to simulate damage which might be caused by the ferrule of a drain cleaning rod being impacted against the inside of the pipe or fitting during cleaning operations and is intended to ensure the structural integrity of the inner layer. A segment of pipe or a section from a fitting is subjected to impact on its internal surface whilst fully supported by its external surface.

(02/20) Test Method for Resistance to Sharp Objects

12 (02/20) The test is intended to simulate the effect of penetration due to sharp aggregate and is intended to exclude ducts with particularly thin wall section.

NG 521 (02/20) Low Pressure High Volume Jetting of Drainage Systems

(02/20) General

1 (02/20) The drainage system to be cleaned should be stated in contract specific Appendix 5/1. The details should include the locations, type of pipe material, where known, pipe diameter or state the type of system if not piped.

2 (02/20) Where pitch fibre, porous concrete or perforated pipes are known to be present, these should be identified in contract specific Appendix 5/1 and the Contractor made aware of their presence.

3 (02/20) If the works are required to be detailed in accordance with contract specific Appendix 90/1 of Series 9000 (MCHW 5.9.3), the compiler's attention is drawn to the need to ensure also that the relevant sections of the Method of Measurement for the Series 9000 are included (and amended if necessary) within the scheme specific documents.

(02/20) Jetting of Piped Drainage Systems

4 (02/20) An alternative method of cleaning should be used for porous concrete or perforated pipes. There is a risk to the structural integrity of the porous pipes and a risk that exfiltration will enter the unbound pavement layers and wash out fine material in both instances. This may cause voids to form and result in premature pavement failure. Pitch fibre pipes should be treated as "unknown/structurally damaged" in accordance with Table 5/12.

(02/20) Jetting of Linear Drainage Systems

5 (02/20) The type of linear drainage system should be detailed in contract specific Appendix 5/1.

6 (02/20) The use of a high pressure lance may be used externally to clear gratings or slots of linear drainage systems.

(02/20) Silt Removal

7 (02/20) The pipeline should be deemed to be clean when the silt content of the cross-sectional area of the pipe is between 0 and 10% for pipes ≤ 600 mm and between 0 and 5% for pipes > 600 mm diameter.

(02/20) Health and Safety

8 (02/20) The safety aspects to be addressed relating to jetting are, practices concerning high pressure water, possible infection from the drain contents, working on the highway and in some circumstances, working in confined spaces.

(02/20) **Equipment**

9 (02/20) Jet heads with nozzles set at approximately 20° to the pipe surface have a low jet angle and are unlikely to cause damage to the pipeline. Fan jets have low jet angles and are widely dissipated and hence unlikely to cause damage to the pipeline.

NG 523 (02/20) Grassed Surface Water Channels

- 1 (02/20) Grassed channel construction should be undertaken in early spring or early autumn to avoid long establishment times in winter and hot/dry periods in summer.
- 2 (02/20) A geo-grid is usually held in place by U-shaped steel pins or staples.
- 3 (02/20) During construction of the channels, temporary measures may be needed to prevent surface runoff from the pavement or verge washing away the topsoil or surcharging the fin drain.
- 4 (02/20) Topsoil deeper than 50 mm will encourage the growth of weeds and other forms of vegetation.
- 5 (02/20) Turfing offers advantages over hydro-seeding in that it will give a much greater level of initial protection to the topsoil and hydro-seeding is dependent on the quality of the seed mixture and the fibre reinforcement.
- 6 (02/20) Where the channel is seeded directly, a minimal depth of topsoil (but within the specification) will enable the grass roots to penetrate the subsoil and bond the two layers together.
- 7 (02/20) Compiler to select grass mix based on options in CD521 Appendix J.

NG 524 (02/20) Combined Surface Water Channel and Pipe (Concrete)

- 1 (02/20) The compiler should complete contract specific Appendix 11/1 for Combined Surface Water Channel and Pipe (Concrete).

NG 525 (02/20) Reservoir Pavements

- 1 (02/20) During construction, reservoir pavements should be protected from construction debris and soil-contaminated storm water runoff from other parts of the site.
- 2 (02/20) Debris and sediment laden runoff generated during construction can cause clogging of the reservoir pavement.
- 3 (02/20) Reservoir pavements should be built late in the construction schedule when most of the earthworks, including grading and landscaping, are complete.
- 4 (02/20) If it is not possible to programme construction of reservoir pavements late in the works, specific measures may be required to isolate and protect the reservoir pavement.
- 5 (02/20) Where a reservoir pavement requires repair or reinstatement, materials shall be replaced on a like for like basis.
- 6 (02/20) The repair technique to be adopted depends on the degree and extent of the degradation.
- 7 (02/20) For surface damage limited to a few square metres, for example in the event of incidents of pollution or fire, repair of pervious surfaces may be carried out using conventional materials.
- 8 (02/20) When damage is localised and limited to loss of material by fretting under traffic, or gouging as a result of an accident, it is not generally necessary to intervene.
- 9 (02/20) If it is necessary to maintain the existing pervious nature of the pavement, the damaged surfacing material should be removed and repaired.
- 10 (02/20) Planing or cutting may be used in removal of the damaged surface.
- 11 (02/20) Vertical joints should be prepared by application of a suitable bonding agent before repair.

(02/20) NG SAMPLE CONTRACT SPECIFIC APPENDIX 5/1: DRAINAGE REQUIREMENTS

[Note to compiler: This should include:]

- 1 (02/20) the basis of the hydraulic design of the system on which the Contractor should submit his proposals for pipe types and makes [501.3, 8005.1];
- 2 (02/20) a schedule of permitted alternative pipe and bedding combinations; *[which should be determined in accordance with CD 533 (DMRB 4.2.5)]* [503.3, 8005.7] and list of pipelines to be constructed other than in a trench [608.8];
- 3 (02/20) grading and geometrical requirements for filter drain material Type C;
- 4 (02/20) values of pipe stiffness class, creep ratio and impact resistance for thermoplastics pipes;
- 5 (02/20) plate thicknesses for bolted segmental plate pipes [501.4(i)] and minimum plate thickness for corrugated steel pipes of lock seam fabrication if different from sub-Clause 501.4;
- 6 (02/20) whether corrugated steel pipes are to have additional protection of hot-applied bitumen [501.5];
- 7 (02/20) where sulfate-resisting Portland cement is required for concrete pipes [Table 5/1];
- 8 (02/20) pipe classification to BS EN 14364 and BS EN 1796 for GRP pipes for drainage [Table 5/1];
- 9 (02/20) laying method for corrugated coilable perforated pipes [503.2];
- 10 (02/20) details of materials if differing from the requirements of sub-Clause 503.3(v);
- 11 (02/20) whether joints in surface water drains should be watertight or partly watertight [504.2];
- 12 (02/20) where rigid joints may be used [504.3];
- 13 (02/20) backfilling requirements differing from sub-Clause 505.2; references to drawings giving locations where backfilling is required to a level other than that specified in sub-Clause 505.13;
- 14 (02/20) where saddles may be used [508.9 and 508.7NI];
- 15 (02/20) material classification for backfilling filter drains and permeability requirements including test details [509.8];
- 16 (02/20) references to drawings showing requirements for connecting existing drains to new drains and details of special connecting pipes [506.1, 8005.19];
- 17 (02/20) requirements for sealing, removal or grouting of existing drains [506.3];
- 18 (02/20) details of connecting existing land drains [511.1];
- 19 (02/20) whether severed mole drains are to be intercepted by construction of a land drain [511.4];
- 20 (02/20) requirements for backfilling mole channels if different from the requirements of sub-Clause 511.4;
- 21 (02/20) references to drawings which show chamber types [507.1];
- 22 (02/20) particular requirements for precast and cast in-situ chambers if differing from the requirements of sub-Clause 507.4 [507.4];
- 23 (02/20) particular requirements for corrugated galvanized steel chambers [507.5];
- 24 (02/20) requirements for testing chambers for foul and surface water drains for watertightness [507.8] and carrier, foul and filter drain surveys by Closed Circuit Television (CCTV) *[this requirement to be stated in Appendix 90/1 (MCHW 9.5.3)]* [509.5];
- 25 (02/20) details of chamber covers, gratings and frames [507.9] and details for special duty covers for use in carriageways [507.13]; requirements for minimum waterway area to gratings for catchpits [507.14]; Polished Skid Resistance Value (PSRV) for chamber covers [507.9];

- 26 (02/20) the classes and sizes of cast iron and steel gully gratings [508.6 and 508.4NI];
- 27 (02/20) requirements for gully gratings if different from the requirements of sub-Clause 508.7 and 508.5NI;
- 28 (02/20) requirements for setting existing covers and gratings to level if different from the requirements of sub-Clauses 507.18 and 508.10 and 508.8NI;
- 29 (05/06) whether gullies are to be trapped, untrapped or sumpless [508.1]; details of in situ concrete gullies [508.3];
- 30 (02/20) references to drawings showing requirements for filling to pipe bays and verges if different from the requirements of sub-Clause 512.1;
- 31 (02/20) requirements for permeable backing if different from the requirements of sub-Clauses 513.1 and 513.2;
- 32 (02/20) requirements for the cleaning of chambers, gullies and drains [509.5];
- 33 (02/20) requirements for cleaning of existing drainage systems – Clause 520 [520.1 and 520.4];
- 34 (02/20) requirements for rapid setting bedding materials and the locations where they will be required [507.18];
- 35 (02/20) requirements for the cleaning of existing drainage systems using low pressure high volume jetting [521.1]; details of drainage system [521.2] and pipe material [521.3];
- 36 (02/20) limiting distance for deposition of materials referred to in sub-Clauses 503.4, 503.5, 505.9 and 505.10;
- 37 (02/20) requirements for geotextiles [505.3].

(02/20) NG SAMPLE CONTRACT SPECIFIC APPENDIX 5/2: SERVICE DUCT REQUIREMENTS

[Note to compiler: This should include:]

- 1 (02/20) details of duct construction [503.7]
[cross-reference should be made to HCD drawing no. I2 where appropriate];
- 2 (02/20) a schedule of service duct requirements [similar to those in Appendix 5/1 for pipes];
- 3 (02/20) details of permanent marker blocks and location posts required for service ducts [505.14] [cross-reference should be made to HCD drawing no. I1 where appropriate];
- 4 (02/20) colour coding of ducts [Refer to 501.7, 518.4 and Health and Safety Executive booklet HS(G)47];
- 5 (02/20) references to drawings which show chamber types;
- 6 (02/20) duct classification to BS EN 14364 and BS EN 1796 for GRP ducts [Table 5/2];
- 7 (02/20) resistance to bending requirements for thermoplastic ducts [Table 5/2];
- 8 (02/20) if ducts require water tight joints [504.2].

(02/20) **NG SAMPLE CONTRACT SPECIFIC APPENDIX 5/3: SURFACE WATER CHANNELS AND DRAINAGE CHANNEL BLOCKS**

[Note to compiler: State here specific requirements cross-referring to the appropriate drawing numbers, including HCD Series B and F drawings as listed in Appendix 0/4 of the Contract document] [510.1]

- 1 (02/20) Requirements for the cross sectional and longitudinal profile of grassed surface water channels.
- 2 (02/20) The duration of protection required from a biodegradable geosynthetic reinforcement used in conjunction with the grassed surface water channel.
- 3 (02/20) Requirements for location, profile and gradient drawings of grassed surface water channels.
- 4 (02/20) Requirements for drawings locations, reinforcing mesh (BS4483), concrete designation, minimum cover requirements, profile, and hydraulic capacity to be included for combined surface water channel and pipe.
- 5 (02/20) Requirements for grass mix [NG 523.7].

(02/20) **NG SAMPLE CONTRACT SPECIFIC APPENDIX 5/4: FIN DRAINS AND NARROW FILTER DRAINS**

[Note to compiler: This should include:]

- 1 (02/20) Permitted alternative types of fin drain and narrow filter drain.
[Normally the choice of type of fin or narrow filter drain should be left to the Contractor.]
- 2 (02/20) Drawing references showing locations.
- 3 (02/20) The maximum permissible O_{90} determined from the pore size distribution curve of the geotextile [514.4 (v) and 515.3].
- 4 (02/20) The permeability of the geotextile [514.4 (vi) and 515.3].
- 5 (02/20) The long term in-plane flow for fin drains [514.6].
- 6 (02/20) Pipe diameters [514.11 and 515.6].
- 7 (02/20) Trench backfill material for fin drain if not as-dug material [514.10].
- 8 (02/20) Category for tolerances at mid-size sieves in Type 8 and Type 9 filter material [515.5].
- 9 (02/20) Permeability of granular material in narrow filter drain where required [515.5].
- 10 (02/20) Maximum drain slope angle if different from 15% [514.11 and 515.6].
- 11 (02/20) Dimensions of fin drains and narrow filter drains if different from the requirements of sub-Clauses 514.11 and 515.6.
- 12 (02/20) References to drawings and/or schedules which show required levels [514.12 and 515.7].

(02/20) **NG SAMPLE CONTRACT SPECIFIC APPENDIX 5/5: COMBINED DRAINAGE AND KERB SYSTEMS**

[Note to compiler: Include here:]

- 1 (02/20) Drawing references showing locations, etc.
- 2 (02/20) Limiting dimensions:
 - (i) Maximum width and depth of units *[if applicable]* [516.4].
 - (ii) Kerb upstand.
 - (iii) Kerb profile *[if applicable]*.
 - (iv) Dimensions of side-entry inlets of units to be used in or adjacent to porous asphalt [516.5].
- 3 (02/20) Strength requirements
[units must be specified as class D or class C. Class D units must be used where there is a possibility of impact from all types of road vehicle that are permitted on trunk roads including motorways. Class C units must only be installed in locations which are protected from direct traffic loading, e.g. in areas behind safety barriers. Further advice on other permitted classes can be found in clause 5 of BS EN 1433.] [516.6]
- 4 (02/20) Hydraulic design parameters [516.1 and 516.3]
- 5 (02/20) Any special fittings required [516.10].
- 6 (02/20) Surveying requirements with pre-cleansing requirements [516.11]

(02/20) **NG SAMPLE CONTRACT SPECIFIC APPENDIX 5/6: LINEAR DRAINAGE CHANNEL SYSTEMS**

[Note to compiler: Include, as appropriate, the various requirements for the prefabricated and the in-situ linear drainage channel systems here:]

- 1** (02/20) Drawing references showing locations, etc.
- 2** (02/20) Limiting dimensions:
 - i) maximum width and depth of units *[517.4 and 1103.1]*;
 - ii) dimensions of side-entry inlets of units to be used in or adjacent to porous asphalt *[517.5]*.
- 3** (02/20) Hydraulic design parameters *[517.1 and 517.3]*
- 4** (02/20) Strength requirements
[units must be specified as class D or class C. Class D units must be used where there is a possibility of impact from all types of road vehicle that are permitted on trunk roads including motorways. Class C units must only be installed in locations which are protected from direct traffic loading, e.g. in areas behind safety barriers. Further advice on other permitted classes can be found in clause 5 of BS EN 1433.] [516.6]
- 5** (02/20) Weathering Resistance
requirement relating to the grade of weathering resistance for drainage channels made of concrete
[see clause 6.3.3.3 of BS EN 1433] [517.7]
- 6** (02/20) Any special fittings required *[517.10]*.
- 7** (02/20) Survey requirements including pre-cleansing requirements *[517.11]*.

(02/20) NG SAMPLE CONTRACT SPECIFIC APPENDIX 5/7: THERMOPLASTICS STRUCTURAL WALL PIPES AND FITTINGS

Information to be provided by the Contractor

The Contractor shall provide the following information, in accordance with sub-Clause 518.2, for the range of pipes and fittings (to be verified by the Certification body – see sub-Clause 518.15):

- 1 (02/20) Technical drawings showing dimensions and tolerances including sealing rings and weight per metre, together with properties, as specified in sub-Clauses 518.3 and 518.5.
- 2 (02/20) Material specification, as required in sub-Clause 518.2:

Table 1: (02/20) Unplasticised polyvinyl-chloride (PVC-U)

Property	Test method reference	Specification
Tensile Properties	BS EN ISO 6259, BS EN ISO 527-1	
Vicat	BS EN 727	
Longitudinal reversion	BS EN 743	
K-value	BS EN 922	
PVC content	EN 1905	
Density	BS EN ISO 1183-3, ISO 4451	
Heat Reversion	ISO 12091	
Effects of heating (injection moulded fittings only)	BS EN 763	

Table 2: (02/20) Polyethylene (PE)

Property	Test method reference	Specification
Tensile Properties	BS EN ISO 6259, BS EN ISO 527-1	
Oxygen induction time	BS EN 728	
Melt Flow Rate	BS EN ISO 1133	
Density	BS EN ISO 1183-3, ISO 4451	
Melt Flow Rate	ISO 4440	
Heat Reversion	ISO 12091	
Effects of heating (injection moulded fittings only)	BS EN 763	

Table 3: (02/20) Polypropylene (PP)

Property	Test method reference	Specification
Tensile Properties	BS EN ISO 6259, BS EN ISO 527-1	
Oxygen induction time	BS EN 728	
Melt Flow Rate	BS EN ISO 1133	
Density	BS EN ISO 1183-3, ISO 4451	
Heat Reversion	ISO 12091	
Effects of heating (injection moulded fittings only)	BS EN 763	

(02/20) NG SAMPLE CONTRACT SPECIFIC APPENDIX 5/8: MAINTENANCE PLANS FOR SOAKAWAYS

[Compiler to include the following:]

- 1 (02/20) Commissioning phase for soakaways.
- 2 (02/20) Routine inspections required to determine the rate of accumulation of sediment in soakaways and pre-discharge treatment devices.
- 3 (02/20) Timetable for submission of the inspection and maintenance plan(s).